

# **RHZ SERIES**

High-performance unit equipment for hazardous locations. Class I, Div. 2; Groups A, B, C & D, Class II Div 2: Groups F & G Class III

#### FEATURES

- Evaluated to CSA C22.2 No.141 15 and No.137-M1981 for use in hazardous locations: Class I Division 2, Groups A, B, C and D; Class II Division 2, Groups F and G and Class III
- Nema-4X protection grade against liquids and dust
- Fiberglass light-grey housing with captive screws; stainless steel hardware
- High ambient temperature up to 50°C (122°F); optional cold-weather -40°C to 50°C (-40°F to 122°F)
- High-temperature Lead-Calcium battery
- High-efficacy LED emergency heads outperform traditional 50W halogen lamps.
- Innovative lamp design: four-LED and dual-driver provide illumination even in case of unexpected component failure
- Compact size: 0.46 cubic feet
- Simple and easy to install on walls, columns or struts on vertical position. For installation on columns use mounting bracket catalogue number: PMK1-R (order separately) \*See warning in installation drawing below
- Standard infra-red remote control included in all models: allows testing the equipment without the need to climb a ladder. Distance range up to 30 ft. Universal, one Remote Control may test all the units on the job.
- Optional Audible or Non-Audible Auto-Diagnostic
- Optional Nexus<sup>®</sup> central monitoring system
- Advanced diagnostics capabilities (specific load requirements)
- 1 Year limited warranty See warranty details at: www.tnb.ca/en/brands/ready-lite

### **REMOTE TEST CONTROL**



### new product



### TYPICAL SPECIFICATIONS

Supply and install **Ready-Lite® RHZ Series** of battery unit equipment. The unit enclosure shall have a compressionmolded fiberglass construction and shall be equipped with a hinged, overlapping cover. The cover shall include a 3/16" wide rubber gasket and shall fasten with two stainless-steel captive screws. The enclosure shall have lateral flanges with holes for easy installation on the wall and shall include two entries for vertical and horizontal conduit and wire access. The installation kit shall include two cable glands of size 1/2" NPT, rated for hazardous locations. The emergency lighting heads shall be installed at the bottom of the cabinet and have the electrical cable passing through the swivel via water-tight bushings. The heads shall be made of die-cast aluminum and have a flat square lens made of UV-stabilized clear polycarbonate. The lens shall be sealed with a rubber gasket and be fixed with an aluminum frame and 6 (six) tamper-proof screws. Each head shall include four (4) LED lamps and two independent LED drivers with electrical connections allowing for lighting even in case of unexpected component failure. Each emergency head shall have an input voltage range of 12 – 24Vdc and a constant power regulation, providing stable illumination during variations of the battery discharge voltage.

When specified, the unit equipment with Auto-Diagnostic option shall execute automatic tests for one minute every 30 days, 10 minutes every sixth month and 30 minutes every 12 months. In case of a functional failure detection: the unit equipment pilot light shall change color from green to red and signal a service alarm with specific flashing codes: battery or lamp disconnect, battery failure, charger failure, lamp failure, or heater failure (cold-weather option). A label installed near the pilot light shall contain the legend with diagnostic codes. The unit equipment shall come standard with an infrared remote test control.

The unit equipment shall be rated NEMA-4X for hose-down applications. The equipment shall be cUL listed to CSA22.2 Standard No.141-15 and No.137-M1981 for hazardous locations: Class I Division 2, Groups A, B, C and D; Class II Division 2, Groups F and G and Class III.


The unit shall be Ready-Lite® model: \_

### POWER CONSUMPTION AND UNIT RATING

| MODEL    | AC SPECS |        |        | WATTAGE CAPACITY |      |      |       |       |
|----------|----------|--------|--------|------------------|------|------|-------|-------|
|          | 120VAC   | 277VAC | 347VAC | 30MIN            | 1H00 | 1H30 | 2H00* | 4H00* |
| 1275     | 0.20A    | 0.10A  | 0.07A  | 75               | 40   | 30   | 24    | 15    |
| 24150    | 0.37A    | 0.18A  | 0.12A  | 150              | 80   | 90   | 48    | 30    |
| 1275-CW  | 0.40A    | 0.25A  | 0.15A  | 75               | 40   | 30   | N/A*  | N/A*  |
| 24150-CW | 0.50A    | 0.25A  | 0.20A  | 150              | 80   | 90   | N/A*  | N/A*  |

### DIMENSIONS

Dimensions are approximate and subject to change.



\*WARNING: Mounting column must be anchored at both ends: floor and ceiling.

## **READY-LITE**

116



### **CLASSIFICATION FOR HAZARDOUS LOCATIONS**

| TYPE OF         | CLASSIFICATION                                | TEMPERATURE CODE   |                    |  |
|-----------------|---|--------------------|--------------------|--|
| EMERGENCY HEADS | CLASSIFICATION                                | $TA = 40^{\circ}C$ | $TA = 50^{\circ}C$ |  |
| 115             | Class I Division 2 Groups A, B, C and D       | T3C                | ТЗА                |  |
| L15             | Class II Division 2 Groups F and G; Class III | Т5                 | Т5                 |  |
| No Heads        | Class I Division 2 Groups A, B, C and D       | T4A                |                    |  |
|                 | Class II Division 2 Groups F and G; Class III | T6                 |                    |  |


### **PHOTOMETRY PERFORMANCE**

Whether installed indoors or outdoors, the **RHZ Series** of LED emergency lights deliver a stable and consistent illumination on the path of egress for a wide range of mounting heights.

| LED LAMP | POWER (W) | TOTAL LUMENS | OUTPERFORMS THE INCANDESCENT LAMPS |
|----------|-----------|--------------|------------------------------------|
| L15      | 15W       | 1320         | 50W MR16-IR Halogen                |

Industrial environment: wall mounted equipment, reflectances: 10/10/10; 6-ft wide illumination path. Illumination as per NFPA101; Average: 1fc; Min: 0.1fc; Max/min< 40:1

| MOUNTING HEIGHT | SPACING CENTRE-TO-CENTRE (FEET) |  |  |
|-----------------|---------------------------------|--|--|
| MOONTING HEIGHT | LAMP L15 / 15W, 1300LM          |  |  |
| 10 ft           | 140                             |  |  |
| 15 ft           | 135                             |  |  |
| 20 ft           | 130                             |  |  |
| 25 ft           | 120                             |  |  |
| 30 ft           | 110                             |  |  |



#### **ORDERING INFORMATION**

| SERIES  | UNIT CAPACITY   | NUMBER OF<br>Heads                         | LED LAMP<br>Type     | FUNCTIONS  | OPTIONS  |
|---|---|--|----------------------|--|--|
| RHZ= Hazardous<br>locations.<br>Cl.I D2,<br>Cl.II D2,<br>Cl.III | 1275= 12V-75W; 10°C<br>to 50°C Amb<br>(10°F to 122°F)<br>24150= 24V-150W;<br>10°C to 50°C<br>Amb (10°F to<br>122°F) | 0= no heads<br>1= one head<br>2= two heads | L15= 12V,<br>24V-15W | AD= auto-diagnostic, audible <sup>1</sup><br>ADN= auto-diagnostic, non-audible <sup>1</sup><br>Blank= no auto-diagnostic function<br>NEXRF= Nexus <sup>®</sup> wireless system<br>interface <sup>1</sup> | <ul> <li>CW= Cold-weather, 120/347V, -40°C to 50°C Amb<br/>(-40°F to 58°F)</li> <li>CW2= (120/277V) Cold-weather (-40°C to 50°C Amb)</li> <li>D3= time delay (15 minutes)</li> <li>RFI= radio frequency interference filter<br/>(120/277VAC)</li> <li>RF3= radio frequency interference filter (347VAC)<sup>1</sup></li> <li>U2= 120/277VAC input</li> <li>U122= 120/208/220-240V 50/60Hz input<sup>1</sup></li> </ul> |
|   |   |  |                      | <sup>1</sup> Minimum lamp load required: 20% of unit capacity  | <sup>1</sup> 12V units only, not available with Nexus <sup>®</sup> & CW  |
|   |   |  |                      | For more information, please consult<br>your sales representative.   | Not available with CW option<br><b>PMK1-R</b> = universal mounting bracket (sold seperately)   |



# **RHZ SERIES**

High-performance unit equipment for hazardous locations. Class I, Div. 2; Groups A, B, C & D, Class II Div 2; Groups F & G Class III

### **READY-LITE**

