

Steel City Pre-Ganged boxes

Accessories and covers



3G 1/2 3/4CN



SGP



2 GC



Cat. No.	Volume (Cu. in.)	Number of Gangs	Width (in.)	Knockouts			Accepts
				sides	bottom	ends	
Pre-ganged boxes – 1 5/8 in. deep x 4 1/2 in. high							
2G 1/2 3/4CN	45.0	2	6 13/16	4x 1/2; 4x 3/4	3x 1/2; 2x 3/4	2x 1/2; 2x 3/4	2 GC or 3 GC
3G 1/2 3/4CN	58.0	3	8 5/8	6x 1/2; 4x 3/4	6x 1/2; 4x 3/4	2x 1/2; 2x 3/4	3 GC or 4 GC
4G 1/2 & 3/4-CN	70.0	4	10 7/16	6x 1/2; 6x 3/4	6x 1/2; 4x 3/4	2x 1/2; 2x 3/4	4 GC or 5 GC
5G 1/2 3/4CN	85.0	5	12 1/4	8x 1/2; 6x 3/4	6x 1/2; 4x 3/4	2x 1/2; 2x 3/4	5 GC or 6 GC
6G 1/2 3/4CN	98.0	6	14 1/16	8x 1/2; 8x 3/4	6x 1/2; 4x 3/4	2x 1/2; 2x 3/4	6 GC



Cat. No.	Volume (Cu. in.)	Number of Gangs	Width (in.)	Accepts
3/4 in. raised covers – 4 13/16 in. high				
2 GC	8.5	2	7	2G 1/2 3/4CN
3 GC	13.5	3	8 25/32	2G 1/2 3/4CN or 3G 1/2 3/4CN
4 GC	18.3	4	10 5/8	3G 1/2 3/4CN or 4G 1/2 & 3/4-CN
5 GC	23.0	5	12 7/16	4G 1/2 & 3/4-CN or 5G 1/2 3/4CN
6 GC	28.3	6	14 1/4	5G 1/2 3/4CN or 6G 1/2 3/4CN

3G 1/2 3/4CN or 4G 1/2 & 3/4-CN, all CIGBC covers have tapped holes spaced to accommodate standard switches and receptacles. Lateral spacing 1 13/16 in.

Cat. No.	Description
----------	-------------

Low voltage partitions (steel)

SGP	Steel low voltage partition for use with Steel City Pre-Ganged boxes, when conductors are connected to different sources
-----	--

In accordance with C.E.C. 2012 Edition, Rule 12-3030: Conductors that are connected to different power or distribution transformers or other different sources of voltage shall not be installed in the same box, cabinet, or fitting unless a barrier of sheet steel not less than 1.3 mm thick or a flame-retardant nonmetallic insulating material not less than 1.6 mm in thickness is used to divide the space into separate compartments for the conductors of each system.